



Alwin Manufacturing Co, Inc., d.b.a. E-Z Taping Systems® Design Number EZT/FC 120-08 Joint Tape Flame Fighter Fire Tape® ASTM E119, UL 263, NFPA 251, CAN/ULC S101 Fire Resistance Rating – 2 hours







- 1. GYPSUM BOARD Select any 2-hour, fireresistance rated, loadbearing, floor-ceiling assembly comprised of steel or wood, joists or trusses, with a gypsum board ceiling supported by resilient steel framing (Item 2). under Intertek's Design Number Designated FC-120, Floor-Ceiling Assembly, or under UL's Category BXUV and ULC's Category BXUV7, Floor-Ceilings: Wood and Steel Assembly Combinations, Design Numbers 500-599 under Designation L; or under the Gypsum Association's GA-600, Fire Resistance Design Manual under GA File Numbers 4300-5999 under Designation FC, Wood Framed Floor-Ceilings and Steel Framed Floor-Ceilings Wood Floor. Gypsum board panel's nominal thickness shall be as specified in the specific Intertek or UL Design Number selected. Gypsum board comply with panels shall ASTM C1396/C1396M, Standard Specification for Gypsum Board; ASTM C1177 Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; or ASTM C1658 Standard Specification for Glass Mat Gypsum Panels and be Listed and Labeled under a recognized third-party Listing and Follow-up Program. Gypsum board panels shall be installed in accordance with ASTM C840, Standard Specification for Application and Finishing of Gypsum Board, and GA-216 Application and Finishing of Gypsum Panel Products. All joints of gypsum board panels shall be tightly abutted and centered of steel ceiling framing (Item 2).
- 2. RESILIENT STEEL FRAMING Use resilient steel framing as specified in the specific

Design Number compliant with Item 1 for size and gauge as well as attachments and length in relationship to distance between perimeter wall steel ceiling framing (not shown). Ceiling cavity can be either empty or filled with insulation as specified in the specific Design Number compliant with Item 1.

- 3. FASTENERS Spacing pattern, length, and diameter of fasteners shall be as specified in the specific Design Number compliant with Item 1. Use Type S screws for attaching gypsum board panels (Item 1) to light gauge steel ceiling framing (Item 2) and screws shall comply with ASTM C 1002, Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.
- CERTIFIED MANUFACTURER: E-Z Taping Systems[®]
 CERTIFIED PRODUCT: Joint Tape

CERTIFIED MODEL: Flame Fighter Fire Tape®

JOINT TAPE – Use patented, multi-layer, fiberglass reinforced, Flame Fighter Fire Tape[®] with pressure sensitive adhesive tested to requirements for joint tape under ASTM C474, *Standard Test Methods for Joint Treatment Materials for Gypsum Board Construction,* complying with requirements for joint tape under ASTM C475, *Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board* for both paper-faced gypsum board




(ASTM E1396) and glass-mat faced gypsum board (ASTM C1177 and ASTM C1658).

A. Flame Fighter Fire Tape[®] is typically used as a Level 1 Finish as described in GA-216, Recommended Specifications for the Application and Finishing of Gypsum Panel Products, (ASTM C840, Standard Specification for Application and Finishing of Gypsum Board) because it is not required to be set in or covered by joint compound. Level 1 Finish applications are typically used in unfinished parts of the building where aesthetics are not an issue, such as in plenum areas above ceilings, in attics, in areas where the assembly would generally be concealed or in building

service corridors; and other areas not normally open to public view or such as in corridors, storage rooms, garages, parking structures, and other similar areas.

B. Center and apply Flame Fighter Fire Tape[®] over the vertical and horizontal gypsum board panel (Item 1) butt joints covering the butt joint and fasteners (Item 4). The butt joints and angles of the gypsum board panels (Item 1) shall be clean, e.g. free of dust or powder, and completely dry prior to the application of Flame Fighter Fire Tape[®]. The pressure sensitive adhesive shall be in complete contact





with the adjacent gypsum board panel (Item 1) surfaces. Apply sufficient pressure to the Flame Fighter Fire Tape® using the E-Z Tape 3-in. plastic knife to aggressively adhere the pressure sensitive adhesive to the gypsum board panels' (Item 1) surfaces. Do not use your hand or any other tool because sufficient adhesion of the Flame Fighter Fire Tape® to the gypsum board panels (Item 1) will not be achieved. Use a corner roller to adhere Flame Fighter Fire Tape[®] to inside and outside gypsum board panel (Item 1) corners, e.g. angles.

C. The exposed outer surface of the Flame Fighter Fire Tape[®] is treated with silicone. Do not overlap Flame Fighter Fire Tape[®] onto itself because it will not adhere to



itself. At intersections of Flame Fighter Fire Tape[®], e.g. "L", "+" and "T", abut the leading edge of the Flame Fighter Fire Tape[®] to the longitudinal edge of the Flame Fighter Fire Tape[®] being intersected.

- D. Joint compound and paint will not adhere to Flame Fighter Fire Tape[®] without the application of an oil-based primer. When paint or a Level 2 or a Level 3 Finish using joint compound is desired, a compatible primer is required to promote adhesion to Flame Fighter Fire Tape[®]. A *Rustoleum[®]* primer called Zinsser[®] Bulls Eye[®] Odorless¹ has been found suitable to coat over Flame Fighter Fire Tape[®] to promote adhesion to Flame Fighter Fire Tape[®].
- E. After the primer is applied in accordance with the manufacturer's instructions and completely dry, joint compound or a latex paint can be applied over Flame Fighter Fire Tape[®].
- F. Use only rolls of Flame Fighter Fire Tape[®] bearing the Intertek Mark for the United States (US) and Canada (C).

¹ http://www.rustoleum.com/product-catalog/consumer-

brands/zinsser/primer-sealers/odorless-oil-base-stain-blocker/